



City of Quincy, Massachusetts
Purchasing Department
1305 Hancock Street
Quincy, MA 02169

Phone: 376-1060

Fax: 376-1074

ADDENDUM No. 2
To
Fence/Guard rail at Fore River Field

RE: BID DUE : March 22, 2016 @ 11:00 a.m.

BID/RFP TITLE: Fence/Guard rail at Fore River Field

The following questions have been raised by a potential bidder and the City's reply follows.

Question #1: At the Pony League Field can you please clarify the total quantity of 6øhigh fence required? The quantity stated in on the bid page doesn't match the drawing. On drawing #1 there is fence (for both dugouts & spectator protection) drawn on both sides of the backstop, however only the 3rd base line has footages listed on it. Are we to match the layout of the 3rd base line fence on the 1st base line?

Answer #1: Yes. The backstop, dugout, spectator fence is the same on the 1st and 3rd base sides.

Question #2: Please indicate post sizes for 12øhigh fence on drawing #3.

Answer #2: Terminal/corner posts are 3" dia and line posts are 2.5" dia SS40 tubing.

Question #3: Please indicate post sizes for 6øfence on drawing #4.

Answer 3: Terminal/corner posts are 3" dia and line posts are 2.5" dia SS40 tubing.

Thank you,

PLEASE SIGN THIS SHEET AND ATTACH IT TO YOUR BID, AS IT IS NOW A PART OF THE BID.

Kathryn R. Hobin

Kathryn R. Hobin
Purchasing Agent

Date: _____

Bidder's Signature: _____